

**LABORATORY ANALYSIS REPORT
Asbestos Identification Report**

Report No: B26838-R1	Report Date: Monday, 27 June 2022
Client: Tamworth Regional Council	Analysed Date: Monday, 27 June 2022
Client Address: Ray Walsh House, 437 Peel Street, Tamworth,NSW, 2340	Laboratory Receival Date: Monday, 27 June 2022
	Sampled Date: Friday, 24 June 2022
	Sampled by : Ben Croxon
Attention: Zac Wheatley	Approved Identifier and Signatory: Kenneth Archer
Sampled From: Ground Floor Comms, Ray Walsh House, 437 Peel Street Tamworth NSW 2340	
Test Method: Polarised Light Microscopy (PLM) including Dispersion Staining (DS), EnviroScience Solutions Pty Ltd in-house laboratory method, in accordance with Australian Standard AS4964-2004 'Method for the qualitative identification of asbestos in bulk samples'. Accredited for compliance with ISO/IEC:17025-Testing. Please note that EnviroScience Solutions does not accept responsibility for the sample submitted in relation to its source.	

Sample Number	Sample Location	Sample Description	Sample Size	Asbestos Detected	Fibres Detected
B26838-S1	Floor	Vermiculite debris	0.3 gm	Yes	Chrysotile
B26838-S2	South Power Switch	Adhesive tape	N.A.	No	Organic
B26838-S3	Desk	Adhesive tape	N.A.	No	Organic
B26838-S4	Central Cabinet	Adhesive tape	N.A.	No	Organic
B26838-S5	Floor	Adhesive tape	N.A.	Yes	Chrysotile, Organic