

**LABORATORY ANALYSIS REPORT**  
**Asbestos Identification Report**

**Report No:** B27950-R1  
**Client:** Tamworth Regional Council  
**Client Address:** Ray Walsh House,  
437 Peel Street,  
Tamworth, NSW, 2340

**Report Date:** Friday, 3 February 2023  
**Analysed Date:** Tuesday, 3 January 2023  
**Laboratory Receival Date:** Friday, 3 February 2023  
**Sampled Date:** Thursday, 2 February 2023  
**Sampled by :** Ben Croxon  
**Approved Identifier and Signatory:** Simone Lobo

**Attention:** Zac Wheatley  
**Sampled From:** 3rd Floor, Ray Walsh House,  
Tamworth, NSW, 2340

**Test Method:** Polarised Light Microscopy (PLM) including Dispersion Staining (DS), EnviroScience Solutions Pty Ltd in-house laboratory method, in accordance with Australian Standard AS4964-2004 'Method for the qualitative identification of asbestos in bulk samples'. Accredited for compliance with ISO/IEC:17025-Testing.  
Please note that EnviroScience Solutions does not accept responsibility for the sample submitted in relation to its source.

| Sample Number | Sample Location           | Sample Description | Sample Size | Asbestos Detected | Fibres Detected |
|---------------|---------------------------|--------------------|-------------|-------------------|-----------------|
| B27950-S1     | 3rd Floor - Hallway Floor | Plasterboard       | 10.4 gm     | No                | Organic         |
| B27950-S2     | 3rd Floor - Hallway Floor | Adhesive tape      | N.A.        | No                | Organic         |