

### LABORATORY ANALYSIS REPORT Asbestos Identification Report

<b>Report No:</b> B26742-R1	<b>Report Date:</b> Friday, 3 June 2022
<b>Client:</b> Tamworth Regional Council	<b>Analysed Date:</b> Friday, 3 June 2022
<b>Client Address:</b> Ray Walsh House, 437 Peel Street, Tamworth,NSW, 2340	<b>Laboratory Receival Date:</b> Friday, 3 June 2022
	<b>Sampled Date:</b> Thursday, 2 June 2022
	<b>Sampled by :</b> Ben Croxon
<b>Attention:</b> Zac Wheatley	<b>Approved Identifier and Signatory:</b> Kenneth Archer
<b>Sampled From:</b> Level 3 - Ray Walsh House, 435-437 Peel Street, Tamworth NSW 2340	
<b>Test Method:</b> Polarised Light Microscopy (PLM) including Dispersion Staining (DS), EnviroScience Solutions Pty Ltd in-house laboratory method, in accordance with Australian Standard AS4964-2004 'Method for the qualitative identification of asbestos in bulk samples'. Accredited for compliance with ISO/IEC:17025-Testing. Please note that EnviroScience Solutions does not accept responsibility for the sample submitted in relation to its source.	

Sample Number	Sample Location	Sample Description	Sample Size	Asbestos Detected	Fibres Detected
B26742-S1	2m North of Light	Adhesive tape	N.A.	No	Organic
B26742-S2	2m East of Light	Adhesive tape	N.A.	No	Organic
B26742-S3	2m South of Light	Adhesive tape	N.A.	No	Organic
B26742-S4	2m West of Light	Adhesive tape	N.A.	No	Organic
B26742-S5	5m North of Light	Adhesive tape	N.A.	No	Organic
B26742-S6	5m East of Light	Adhesive tape	N.A.	No	Organic
B26742-S7	5m South of Light	Adhesive tape	N.A.	No	Organic
B26742-S8	5m West of Light	Adhesive tape	N.A.	No	Organic

**LABORATORY ANALYSIS REPORT**  
**Estimation of Airborne Asbestos Fibres**

<b>Report No:</b> A26742-R1	<b>Report Date:</b> Monday, 6 June 2022
<b>Client:</b> Tamworth Regional Council	<b>Analysed Date:</b> Friday, 3 June 2022
<b>Client Address:</b> Ray Walsh House, 437 Peel Street, Tamworth,NSW, 2340	<b>Laboratory Receival Date:</b> Friday, 3 June 2022
	<b>Sampled Date:</b> Thursday, 2 June 2022
	<b>Sampled By:</b> Ben Croxon
<b>Attention:</b> Zac Wheatley	<b>Approved Counter and Signatory:</b> Kenneth Archer
<b>Sampled From:</b> Level 3 - Ray Walsh House, 435-437 Peel Street, Tamworth NSW 2340	<b>Type of Monitoring:</b> Background Monitoring
<b>Test Method:</b> In accordance with the NOHSC:3003 (2005) Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres (as outlined in the Laboratory Method Manual). Accredited for compliance with ISO/IEC:17025-Testing.	

Sample Number	Sample Location	Time		Flow Rate L/ Min	Results Fibres / Field	Results Fibres / ml
		On	Off			
A26742-S1	North of Light	1230	1410 100 min	3.9	0 /100	< 0.01
A26742-S2	East of Light	1230	1410 100 min	4.0	0 /100	< 0.01
A26742-S3	South of Light	1230	1410 100 min	4.0	0 /100	< 0.01
A26742-S4	West of Light	1230	1410 100 min	4.0	0 /100	< 0.01